

# TEST CERTIFICATE

## Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **Wood/wood composite material**

Kind of material (wood): oak mosaic parquet with factory made sealing

Dimensions: length and width variable, thickness 6 mm

Colour: oak

Surface: even, fine-rough structured, matt

Addition: coating structure:  
1. Substrate: oak mosaic parquet  
2. Sealing: Markant  
(consumption: 1 x ca. 20 ml/m<sup>2</sup> 1 x ca. 80 ml/m<sup>2</sup>)

Producer/supplier: LOBA GmbH & Co. KG  
Leonberger Str. 56-62  
71254 Ditzingen

Client: LOBA GmbH & Co. KG  
Leonberger Str. 56-62  
71254 Ditzingen

Certificate No.: 95322101.001e

Test date: 06.10.2021

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)  
"Testing of floor coverings - Determination of the anti-slip property -  
Workrooms and fields of activities with slip danger - Walking method  
- Ramp test"


Delivery of the test material took place in ready-to-test surface condition.

Test result: Average total acceptance angle: **13,0°**

Assessment: **Classification group of anti-slip property: R10**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 20.10.2021  
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E.V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00 aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

